

## DECLARATION OF PERFORMANCE : CPR016

1. Unique identification code of the product type: **F150C/CPR**

*Multicore cable LiYCY F2 // YSLCY F2 // VC4V-K F2 section from 0.14 mm<sup>2</sup> to 16 mm<sup>2</sup>*

2. Intended uses:

*Flexible cable fire retardant for instrumentation and control, with copper screen for electrical and electromagnetic preventions*

3. Manufacturer: **ELECON CONDUCTORES ELECTRICOS S.A. , C/ Industria nº 2, 08760 Martorell, Barcelona, España. Tel. +34 936822828. Email: [Info@eleconsal.com](mailto:Info@eleconsal.com)**

4. System of evaluation of AVCP: **System 1+ .**

5. Harmonized standard: **EN 50575:2014 +A1:2016.**

Notified agency: **Nº 0370 (LGAI Technological Center S.A (Applus))**

6. Declared performances:

Essential features	AVCP	Performances	Harmonized standard
Reaction to fire	SYSTEM 1+	Cca s2 d0 a3	<b>EN 50575:2014+A1:2016</b>
Hazardous substances		NPD (*)	

(\*)Non-determined benefit

7. The performance of the product identified above is in conformity with the set declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above

FIRMADO

18/12/2018



Juan Francisco Casado Montero  
Industrial Manager



Oscar Garcia Palomino  
Quality Manager.

